

# Standby Electric Generators

## A SOURCE OF EMERGENCY POWER FOR FARMERS

**An emergency source of power is important for any farm with mechanically ventilated production facilities, bulk milk handling equipment, mechanical feeding equipment or facilities requiring constant and continuous heat (such as brooders). On such a farm, a standby electric generator is a good investment, possibly preventing costly losses during a power failure.**

**During disasters such as flood or tornado, relief agencies may provide generators to farmers on an emergency basis.**

### TYPES OF GENERATORS

Standby generators are either engine driven or tractor driven. Either type can be stationary or portable. Engine driven units can be either manual or automatic start. Gasoline-, LP gas- (bottled gas) and diesel-fueled engines are available.

Generators must provide the same type of power at the same voltage and frequency as that supplied by power lines. This is usually 120/240 volt, single phase, 60 cycle alternating current (AC). An air-cooled engine is often used for generators up to 15 kilowatts. A liquid-cooled engine is necessary for generators larger than 15 kilowatts. Engine capacity of 2 to 2 1/4 hp with the proper drive system must be available for each 1,000 watts of generator output.

### SIZE OF GENERATORS

A full-load system will handle the entire farmstead load. Automatic engine-powered, full-load systems will begin to furnish power immediately, or up to 30 seconds after power is off. Smaller and less expensive part-load systems may be enough to handle essential equipment during an emergency.

Power-take-off (PTO) generators are about half as costly as engine-operated units. Under a part-load system, only the most essential equipment is operated at one time. For most farms, this type of system is adequate, provided the generator is sized to start the largest motor. For example, the milk cooler or ventilation fan would need to be operated continuously, but the operation of the silo unloader and mechanical feeding system could be postponed until the milking chores are completed. PTO units can be mounted on a trailer.

### INSTALLATION

Wiring and equipment must be installed in accordance with the National Electrical Code, local ordinances and the requirements of your power supplier. It is essential that you have the proper equipment for disconnecting the generator from public utility lines. Most companies require the installation of a double-pole double-throw transfer switch or its equivalent for this purpose. Check with your electrician or power supply representative for installation, installation instructions and inspection.

## LOCATION AND SAFETY FEATURES

- ◆ Large engine generators should be located in a building, preferably a heated building.
- ◆ Inlet and outlet air ducts must be large enough to carry off excess heat. They should be open at least a half a square foot for each 1,000 watts of generator capacity.
- ◆ Combustion fumes must be carried outdoors safely. Exhaust pipes must be at least 6 inches from combustible material.

## OPERATION

An automatic standby unit should start automatically when power fails, and stop when power is restored. When using an engine-driven generator with a manual start, or when using a tractor driven unit, follow this procedure when power fails:

- ◆ Call your power supplier and advise them of the conditions.
- ◆ Turn off or disconnect all electrical equipment.
- ◆ Position the tractor or engine for belt or PTO drive.
- ◆ Start the unit and bring the generator up to proper speed (1,800 or 3,600 rps). Check on arrangement to carry off exhaust fumes. Be sure there is no danger of fire. The voltmeter will indicate when the generator is ready to carry the load.
- ◆ Put the transfer switch in the generator position.
- ◆ Start the largest electrical motor first, adding other loads when each is up to operating speed. Do not add too much too fast. If the generator cuts out for any reason, repeat the second, third and fourth steps above.
- ◆ Check the voltmeter frequently. If voltage falls below 200 volts for 240 volt service or below 100 volts for 120 volt service, reduce the load on the generator by turning off some electrical equipment.
- ◆ When commercial power is restored, put the transfer switch in normal power position. Then stop the standby unit.

### **Additional resources:**

Your county agricultural agent

### **Related publications:**

UW-Extension publications—

“Standby Electric Power Equipment for the Farm and Home,” (AF2273);

“Electrical Systems for Agricultural Buildings,” (checklist), (A8NE846);

“Electrical Systems for Agricultural Buildings,” (recommended practices), (A8NE845).

“Standby Power,” Illinois Farm Electrification Council, Fact Sheet #2.

## MAINTENANCE

- ◆ Keep the unit clean and in good running order at all times so it will be ready for immediate use. Dust and dirt accumulations on the motor can cause it to overheat when operated.
- ◆ Follow maintenance instructions in manufacturer's manual. A short operation at set intervals will keep the engine in good operating condition. Regularly scheduled warm-ups are necessary to keep a standby engine in working order.